



### Detailed Tender Specification

The 10KVA online UPS should be compliant with following specification.

- Nominal Input Voltage:- 208VAC/220VAC/230VAC/240VAC
- Input Voltage window:- 110VAC~276VAC
- Input Power Factor:- 0.99
- Frequency Range:- 45-55Hz/ 54-66Hz
- Phase:- Single Phase with Ground.
- Voltage Regulation:- <1%
- Freq. Sync Range:- 45-55Hz/54-66Hz
- Freq. Bat Mode:- 50/60Hz +\_0.05Hz
- Output Waveform:- Pure Sine Wave.
- Overload Regulation:- Yes
- User Interface:- Visual [LCD Display]

**Note:-**

**We have 32no. Powersafe sealed lead-acid, battery type Ep 42-12, Volts 12V & Capacity 42Ah which needs to be connected with 10KVA (to be purchased) online UPS.**

#### **(Terms & Conditions)**

**Tenders found deficient in any of the following will be summarily rejected:**

CDR for specified amount as indicated in Tender Notice;  
Letter of Authorization by the Dealers and suppliers from Principal Manufacturer for the equipment, Registration (attested copy) of TIN/VAT of the firm for supply dealing with Farm Machinery/ equipments and apparatus

**Terms of delivery:**

Rates shall be quoted FOR destination (ALTHA, Dean Office, FVSc & AH).

**Other taxes:**

As applicable at the time of delivery of the items.

The maximum possible discount permissible to the Government Departments and Educations Institutions will be applicable.

**Delivery period:**

As specified in the Supply order

**No advance payment will be made.**

Payment of the bills for supplies made shall be released subject to following conditions:

a) The equipment supplied should be strictly as per the make/ specification indicated in the supply order.

b) The working/performance of the equipment is demonstrated to the satisfaction of the Verification Committee Constituted for the purpose by the Competent Authority of the university. The payment will be released after the aforementioned committee records a certificate that **“The equipment has been duly inspected and found as per the specification and made or make ordered for and has shown satisfactory working and performance during demonstration”**.

The installation/ commissioning of the equipment shall be at the risk and responsibility of the supplier and payment shall be released only after installation / commissioning and demonstration of satisfactory working and /or performance of the installed equipment.

**Warranty:**

The equipment shall be covered by a warranty period of at least one year from the date of its satisfactory installation at consignees' place. During the period of warranty, the supplier will provide free servicing and repairs to the equipment. This includes the transportation expenditure incurred for such repairs without any charges involving on undertaking such repairs/ replacement etc.

If the equipment supplied is found to have any manufacturing defect and/or bad workmanship, the equipment shall be replaced at the cost as well as risk and responsibility of the supplier.

**Penalty:**

In case the firm fails to supply the equipment as per the supply order, make/ specification and within the stipulated period, the competent authority of the university will be at liberty to forfeit the CDR and impose any other penalty, as may be deemed fit in case of such an eventuality.

**Jurisdiction:**

Any dispute arising between the parties (University and Supplier) shall be settled within the jurisdiction of Kashmir division of J&K State.